

DRINKING WATER ADVISORY

The Osceola RWS – **South** Water Supply is recommending to boil the water before using for drinking or to use an alternative source.

The Osceola RWS – **South** Water Supply had a problem in the distribution system and the system lost pressure on **June 22nd**. Due to the potential for bacterial contamination, it is being recommended that the water be boiled before using for drinking or cooking or that an alternative source be used. This boil area affects customers in the following **Townships: Union (Sec 1 & 2, 10-12), Dale (Sec 1 & 2, 11 & 12) and Highland (Sec 6&7)**.

IT IS RECOMMENDED NOT TO DRINK THE WATER WITHOUT BOILING IT FIRST. Bring all water to a boil, let it boil for one minute, and let it cool before using, or use bottled water. Boiled or bottled water should be used for drinking, making ice, brushing teeth, and food preparation until further notice. Boiling kills bacteria and other organisms in the water. The water may be used for bathing and other similar purposes.

For more information, please contact **Nate Varner**, Water Superintendent at **712-330-8051** or Osceola County Rural Water System, Inc. at 712-735-6795. General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

When water service is restored, there may be air in your water piping and the water may be discolored. It is recommended to run the first water from a faucet that does not have an aerator screen, such as a bathtub or hose bib. Open the faucet slowly to allow the air to escape. Once the water is flowing, allow the faucet to run until it is clear. The water may be cloudy at first due to air in the water or particles that dislodged as the pipes filled with water. This should clear fairly quickly. If water is cloudy throughout the house and it does not clear after allowing the water to run for several minutes, contact the person listed above.

The system has been repaired, repressurized, and bacteria samples will be collected. This advisory is a precaution until bacterial sample results are available. You will be notified when the results are available and the advisory is lifted. Add or change to explain situation and what is being done.

The system is working with the Iowa Department of Natural Resources to resolve the situation.

This notice is being sent to you by Osceola County Rural Water System

Water Supply. PWSID#: **IA7177701**

Date distributed: **June 24, 2024**